



MCN132



MCB 1P 6kA C-32A 1M

Technical properties

	-	_		
Λ.	rck	site	ecti	IFO

Architecture	
Number of protected poles	1
Number of poles	1 P
Type of pole	1 P
Curve	С
Functions	
Concurrently switching N-neutral	No
Configuration	
Number of modules	1
Connectivity	
Top connection alignement for modular devices	Aligned terminal
Bottom connection alignement for modular devices	Aligned terminal
Main electrical features	
Rated short circuit breaking capacity Icn AC according IEC60898-1	6 kA
Rated operational voltage Ue	230 / 400 V
Type of supply voltage	AC
Frequency	50/60 Hz
Voltage	
Rated insulation voltage	500 V
Rated impulse withstand voltage	4000 V
Electric current	
Rated current	32 A
Rated service breaking capacity Ics AC according IEC 60898-1	6 kA
min/maxi threshold value of the AC thermal operation	1.13 / 1.45 ln
Magnetic regulating currrent	5 / 10 In
min/maxi threshold value of the DC magnetic operation	7 / 15 ln
min/maxi threshold value of the DC thermal operation	1.13 / 1.45 ln
Breaking capacity on 1 pole for IT 400V NF 60947-2	3 kA
Rated short circuit breaking capacity Icn under 230V AC according IEC60898-1	6 kA

Rated utlimate short-circuit breaking capacity lcu under 240V AC IEC 60947-2 Electric current / temperature Rating current -25°C Rating current -20°C Rating current -10°C Rating current -10°C Rating current -5°C Rating current 5°C Rating current 5°C Rating current 10°C Rating current 10°C Rating current 10°C Rating current 5°C Rating current 25°C Rating current 35°C Rating current 40°C Rating current 55°C Rating current 55°C Rating current 55°C Rating current 55°C Rating current 50°C Rating current 60°C Rating current 60°C Rating current 60°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product Width of installed product	10 k/
Rating current -25°C Rating current -10°C Rating current -10°C Rating current -10°C Rating current 5°C Rating current 5°C Rating current 5°C Rating current 5°C Rating current 10°C Rating current 10°C Rating current 20°C Rating current 20°C Rating current 30°C Rating current 30°C Rating current 35°C Rating current 40°C Rating current 5°C Rating current 50°C Rating current 50°C Rating current 50°C Rating current 60°C Rating current 60°C Rating current 60°C Current correction factors Correction factor of rating current for 2 deevices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with Correction factor of magnetic tripping with Correction factor of magnetic tripping with Dimensions Dimensions Depth of installed product Helght of installed product	10 k/
Rating current -20°C Rating current -15°C Rating current -10°C Rating current -10°C Rating current 0°C Rating current 5°C Rating current 10°C Rating current 10°C Rating current 10°C Rating current 10°C Rating current 20°C Rating current 20°C Rating current 20°C Rating current 30°C Rating current 30°C Rating current 40°C Rating current 40°C Rating current 40°C Rating current 50°C Rating current 50°C Rating current 50°C Rating current 60°C Rating current 60°C Rating current 60°C Rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with Correction factor of magnetic tripping with Correction factor of magnetic tripping with Dimensions Depth of installed product Height of installed product	
Rating current -15°C Rating current 5°C Rating current 5°C Rating current 5°C Rating current 10°C Rating current 10°C Rating current 10°C Rating current 15°C Rating current 15°C Rating current 20°C Rating current 30°C Rating current 30°C Rating current 35°C Rating current 40°C Rating current 45°C Rating current 55°C Rating current 55°C Rating current 65°C Rating current 65°C Rating current 67°C Current correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with Height of installed product Height of installed product	41.8
Rating current -10°C Rating current 0°C Rating current 0°C Rating current 10°C Rating current 10°C Rating current 10°C Rating current 10°C Rating current 20°C Rating current 20°C Rating current 20°C Rating current 30°C Rating current 35°C Rating current 40°C Rating current 50°C Rating current 50°C Rating current 50°C Rating current 60°C Rating current 60°C Rating current 60°C Rating current 70°C Current correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with Height of installed product Helght of installed product	41 /
Rating current -5°C Rating current 0°C Rating current 10°C Rating current 10°C Rating current 15°C Rating current 20°C Rating current 25°C Rating current 35°C Rating current 35°C Rating current 35°C Rating current 40°C Rating current 45°C Rating current 55°C Rating current 55°C Rating current 55°C Rating current 60°C Rating current 65°C Rating current 60°C Rating current 60°C Current correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product Height of installed product	40.2
Rating current 0°C Rating current 10°C Rating current 10°C Rating current 115°C Rating current 20°C Rating current 25°C Rating current 30°C Rating current 30°C Rating current 35°C Rating current 40°C Rating current 40°C Rating current 50°C Rating current 50°C Rating current 50°C Rating current 50°C Rating current 60°C Rating current 60°C Rating current 60°C Rating current 60°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product Height of installed product	39.6
Rating current 10°C Rating current 110°C Rating current 120°C Rating current 220°C Rating current 220°C Rating current 30°C Rating current 30°C Rating current 30°C Rating current 40°C Rating current 40°C Rating current 40°C Rating current 50°C Rating current 50°C Rating current 50°C Rating current 60°C Rating current 60°C Rating current 70°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with Correction factor of magnetic tripping with Correction factor of magnetic tripping with Dimensions Depth of installed product Height of installed product	38.5
Rating current 10°C Rating current 20°C Rating current 20°C Rating current 25°C Rating current 30°C Rating current 30°C Rating current 30°C Rating current 40°C Rating current 40°C Rating current 45°C Rating current 55°C Rating current 55°C Rating current 55°C Rating current 60°C Rating current 60°C Rating current 70°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 50 Hz Dimensions Depth of installed product Height of installed product	37.7
Rating current 15°C Rating current 20°C Rating current 20°C Rating current 30°C Rating current 30°C Rating current 30°C Rating current 40°C Rating current 40°C Rating current 45°C Rating current 50°C Rating current 50°C Rating current 60°C Rating current 60°C Rating current 60°C Rating current 70°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product Height of installed product	36.9
Rating current 20°C Rating current 25°C Rating current 30°C Rating current 30°C Rating current 40°C Rating current 40°C Rating current 45°C Rating current 50°C Rating current 50°C Rating current 50°C Rating current 60°C Rating current 60°C Rating current 70°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product Height of installed product	36.1
Rating current 25°C Rating current 30°C Rating current 30°C Rating current 40°C Rating current 40°C Rating current 45°C Rating current 50°C Rating current 55°C Rating current 60°C Rating current 60°C Rating current 60°C Rating current 70°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with But have been supposed by the suppose been	35.2
Rating current 30°C Rating current 40°C Rating current 40°C Rating current 45°C Rating current 50°C Rating current 50°C Rating current 60°C Rating current 60°C Rating current 60°C Rating current 70°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with Dimensions Depth of installed product Height of installed product	34.4
Rating current 40°C Rating current 40°C Rating current 50°C Rating current 50°C Rating current 55°C Rating current 60°C Rating current 60°C Rating current 60°C Rating current 70°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product Height of installed product	33.6
Rating current 40°C Rating current 55°C Rating current 55°C Rating current 55°C Rating current 65°C Rating current 65°C Rating current 65°C Rating current 65°C Rating current 70°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 50 Hz Dimensions Depth of installed product Height of installed product	32 /
Rating current 45°C Rating current 50°C Rating current 50°C Rating current 60°C Rating current 65°C Rating current 65°C Rating current 70°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product Height of installed product	32
Rating current 50°C Rating current 60°C Rating current 60°C Rating current 65°C Rating current 70°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product Height of installed product	31.1
Rating current 55°C Rating current 60°C Rating current 65°C Rating current 70°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product Height of installed product	30.3
Rating current 60°C Rating current 65°C Rating current 70°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product Height of installed product	30
Rating current 65°C Rating current 70°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product Height of installed product	28.7
Rating current 70°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product Height of installed product	27.8
Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product Height of installed product	27
Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product Height of installed product	26.2
devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product Height of installed product	
devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product Height of installed product	
5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product Height of installed product	0.9
devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product Height of installed product	0.
Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product Height of installed product	0.8
200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product Height of installed product	1.
A00 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product Height of installed product	1.
Dimensions Depth of installed product Height of installed product	1.
Depth of installed product Height of installed product	
Height of installed product	
	70 mr
Width of installed product	83 mr
	17.5 mn
Frequency	
Frequency !	50 to 60 H

Power	
Total power loss under IN	4.4 W
Power loss per pole at In	4.4 W
Endurance	
Electric endurance in number of cycles	4000
Number of mechanical operations	20000
Installation, mounting	
Type of top connection for modular devices	with screw
Tightening torque	2,8Nm
Type of Bottom Connection for modular	
devices	Blconnect
Connection	
Connection cross-sect. flexible conductor	1 / 25mm²
Connection cross-sect. rigid cable	1 / 35mm²
Connection cross-section of input and	
output with screws, for massive conductors	1 / 35 mm²
Connection cross section of access and exit with screws, for flexible conductor	1 / 25 mm²
Type of connection	with screw
Standards	
Standard text	EN 60898-1
Safety	
REACH conform	No
RoHS conform	Yes
Halogen free	No
Use conditions	
Operating temperature	-2570 °C
Degree of pollution according to IEC 60664 / IEC 60947-2	2
Class of energy limitation I ² t	
Altitude	2000 m
Air humidity protection	for all climates
Storage/transport temperature	-2580 °C

PD

Aesthetic for B.G. Protection devices