



MCB 2P 25kA C-4A 2M

Technical properties

Architecture	Arc	hit	ect	ure
--------------	-----	-----	-----	-----

	Architecture
without neutral	Neutral position
2	Number of protected poles
2 P	Number of poles
2 P	Type of pole
Din-Rail	Fixing mode
С	Curve
	Functions
No	Concurrently switching N-neutral
	Configuration
2	Number of modules
	Connectivity
Aligned terminal	Top connection alignement for modular devices
Aligned terminal	Bottom connection alignement for modular devices
	Main electrical features
415 V	Rated operational voltage Ue
AC	Type of supply voltage
50/60 Hz	Frequency
	Voltage
500 V	Rated insulation voltage
6000 V	Rated impulse withstand voltage
12 V	Minimum threshold voltage (Ue min)
	Electric current
4 A	Rated current
1.13 / 1.45 ln	min/maxi threshold value of the AC thermal operation
5 / 10 In	Magnetic regulating currrent
5 / 15 ln	min/maxi threshold value of the DC magnetic operation
1.13 / 1.45 ln	min/maxi threshold value of the DC thermal operation

Electric current / temperature

Rating current -20°C Rating current -15°C Rating current -10°C Rating current -5°C Rating current 0°C Rating current 5°C Rating current 10°C Rating current 10°C Rating current 20°C Rating current 20°C Rating current 30°C Rating current 30°C Rating current 30°C Rating current 40°C Rating current 40°C Rating current 50°C Rating current 60°C Rating current 60°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side	4.89 / 4.79 / 4.68 / 4.47 / 4.35 / 4.24 / 4.12 / 4.387 / 3.87 / 3.61 / 3.47 / 3.33 / 3.17 / 3.01 /
Rating current -10°C Rating current 0°C Rating current 5°C Rating current 10°C Rating current 15°C Rating current 20°C Rating current 25°C Rating current 30°C Rating current 30°C Rating current 45°C Rating current 40°C Rating current 50°C Rating current 50°C Rating current 50°C Rating current 50°C Rating current 60°C Rating current 60°C Rating current 70°C Current correction factors Correction factor of rating current for 2	4.99 / 4.89 / 4.79 / 4.68 / 4.58 / 4.47 / 4.35 / 4.24 / 4.12 / 4 / 3.87 / 3.74 / 3.33 / 3.17 / 3.01 / 2.85 /
Rating current -5°C Rating current 0°C Rating current 5°C Rating current 10°C Rating current 15°C Rating current 20°C Rating current 20°C Rating current 30°C Rating current 30°C Rating current 45°C Rating current 40°C Rating current 45°C Rating current 55°C Rating current 50°C Rating current 50°C Rating current 50°C Rating current 60°C Rating current 60°C Current correction factors Correction factor of rating current for 2	4.79 A 4.68 A 4.58 A 4.47 A 4.35 A 4.24 A 4.12 A 3.87 A 3.61 A 3.47 A 3.33 A 3.17 A 3.01 A
Rating current 0°C Rating current 5°C Rating current 10°C Rating current 15°C Rating current 20°C Rating current 25°C Rating current 30°C Rating current 35°C Rating current 40°C Rating current 55°C Rating current 50°C Rating current 50°C Rating current 60°C Rating current 60°C Rating current 60°C Current correction factors Correction factor of rating current for 2	4.68 / 4.58 / 4.47 / 4.35 / 4.24 / 4.12 / 4 / 3.87 / 3.74 / 3.61 / 3.47 / 3.33 / 3.17 /
Rating current 5°C Rating current 10°C Rating current 15°C Rating current 20°C Rating current 25°C Rating current 30°C Rating current 35°C Rating current 40°C Rating current 45°C Rating current 50°C Rating current 50°C Rating current 50°C Rating current 60°C Rating current 60°C Current correction factors Correction factor of rating current for 2	4.58 / 4.47 / 4.35 / 4.24 / 4.12 / 4 / 3.87 / 3.61 / 3.47 / 3.33 / 3.17 / 3.01 /
Rating current 10°C Rating current 15°C Rating current 20°C Rating current 25°C Rating current 30°C Rating current 35°C Rating current 40°C Rating current 40°C Rating current 50°C Rating current 50°C Rating current 50°C Rating current 60°C Rating current 60°C Current correction factors Correction factor of rating current for 2	4.47 / 4.35 / 4.24 / 4.12 / 4 / 3.87 / 3.61 / 3.47 / 3.33 / 3.17 / 3.01 /
Rating current 15°C Rating current 20°C Rating current 25°C Rating current 30°C Rating current 35°C Rating current 40°C Rating current 45°C Rating current 50°C Rating current 50°C Rating current 60°C Rating current 60°C Rating current 60°C Current correction factors Correction factor of rating current for 2	4.35 / 4.24 / 4.12 / 4 / 3.87 / 3.61 / 3.47 / 3.33 / 3.17 / 3.01 /
Rating current 20°C Rating current 25°C Rating current 30°C Rating current 35°C Rating current 40°C Rating current 45°C Rating current 50°C Rating current 50°C Rating current 60°C Rating current 60°C Current correction factors Correction factor of rating current for 2	4.24 / 4.12 / 4 / 3.87 / 3.74 / 3.61 / 3.47 / 3.33 / 3.17 / 3.01 /
Rating current 25°C Rating current 30°C Rating current 35°C Rating current 40°C Rating current 45°C Rating current 50°C Rating current 55°C Rating current 60°C Rating current 60°C Current correction factors Correction factor of rating current for 2	4.12 / 4 / 3.87 / 3.74 / 3.61 / 3.33 / 3.17 / 3.01 /
Rating current 30°C Rating current 35°C Rating current 40°C Rating current 45°C Rating current 50°C Rating current 50°C Rating current 60°C Rating current 65°C Rating current 70°C Current correction factors Correction factor of rating current for 2	3.87 / 3.74 / 3.61 / 3.47 / 3.33 / 3.17 / 3.01 /
Rating current 35°C Rating current 40°C Rating current 45°C Rating current 50°C Rating current 55°C Rating current 60°C Rating current 65°C Rating current 70°C Current correction factors Correction factor of rating current for 2	3.87 <i>x</i> 3.74 <i>x</i> 3.61 <i>x</i> 3.47 <i>x</i> 3.33 <i>x</i> 3.17 <i>x</i> 3.01 <i>x</i>
Rating current 40°C Rating current 45°C Rating current 50°C Rating current 55°C Rating current 60°C Rating current 65°C Rating current 70°C Current correction factors Correction factor of rating current for 2	3.74 / 3.61 / 3.47 / 3.33 / 3.17 / 3.01 /
Rating current 45°C Rating current 50°C Rating current 50°C Rating current 60°C Rating current 65°C Rating current 70°C Current correction factors Correction factor of rating current for 2	3.61 <i>i</i> 3.47 <i>i</i> 3.33 <i>i</i> 3.17 <i>i</i> 3.01 <i>i</i>
Rating current 50°C Rating current 55°C Rating current 60°C Rating current 65°C Rating current 70°C Current correction factors Correction factor of rating current for 2	3.47 <i>i</i> 3.33 <i>i</i> 3.17 <i>i</i> 3.01 <i>i</i>
Rating current 55°C Rating current 60°C Rating current 65°C Rating current 70°C Current correction factors Correction factor of rating current for 2	3.33 <i>i</i> 3.17 <i>i</i> 3.01 <i>i</i>
Rating current 60°C Rating current 65°C Rating current 70°C Current correction factors Correction factor of rating current for 2	3.17
Rating current 65°C Rating current 70°C Current correction factors Correction factor of rating current for 2	3.01
Rating current 65°C Rating current 70°C Current correction factors Correction factor of rating current for 2	
Current correction factors Correction factor of rating current for 2	2.85
Current correction factors Correction factor of rating current for 2	
Correction factor of rating current for 2	
Correction factor of rating current for 3 devices placed side-by-side	0.9
Correction factor of rating current for 4 and 5 devices placed side-by-side	0.
Correction factor of rating current for 6 devices placed side-by-side	0.8
Correction factor of magnetic tripping with 100 Hz	1.
Correction factor of magnetic tripping with 200 Hz	1.
Correction factor of magnetic tripping with 400 Hz	1.
Correction factor of magnetic tripping with 60 Hz	
Dimensions	
Depth of installed product	70 mr
Height of installed product	83 mr
Width of installed product	35 mr
Frequency	
Frequency	50 to 60 H
Power Loca under IN	
Total power loss under IN Power loss per pole at In	5.36 \ 2.71 \

Electric endurance in number of cycles	4000
Number of mechanical operations	20000
Installation, mounting	
Type of top connection for modular devices	with screw
Tightening torque	2,8Nm
Type of top rail clip for modular devices	NA
Type of bottom rail clip for modular devices	plastic
Type of Bottom Connection for modular devices	Blconnect
Top removability for modular devices	Yes
Bottom removability for modular devices	Yes
Connection	
Connection cross-section of input and output with screws, for massive conductors	1 / 35 mm²
Connection cross section of access and exit with screws, for flexible conductor	1 / 25 mm²
Type of connection	with screw
Equipment	
With transparent product label holder	Yes
Standards	
European directive WEEE	concerned
Safety	
Protection index IP	IP20
Use conditions	
Operating temperature	-2570 °C
Degree of pollution according to IEC 60664 / IEC 60947-2	2
Class of energy limitation I²t	3
Altitude	2000 m
Air humidity protection	for all climates
Storage/transport temperature	-2580 °C