

3 kA

6 kA



MCN206A

MCB 2P 6kA C-6A 2M

Technical characteristics

Technical characteristics	
Architecture	
Number of protected poles	2
Number of poles	2 P
Type of pole	2 P
Curve	С
Functions	
Concurrently switching N-neutral	No
Configuration	
Number of modules	2
Connectivity	
Top connection alignement for modular devices	Aligned terminal
Bottom connection alignement for modular devices	Aligned terminal
Main electrical features	
Rated short circuit breaking capacity Icn AC according IEC60898-1	6 kA
Rated operational voltage Ue	400 V
Type of supply voltage	AC
Frequency	50/60 Hz
Voltage	
Rated insulation voltage	500 V
Rated impulse withstand voltage	4000 V
Electric current	
Rated current	6 A
Rated service breaking capacity Ics AC according IEC 60898-1	6 kA
min/maxi threshold value of the AC thermal operation	1.13 / 1.45 In
Magnetic regulating currrent	5 / 10 In
min/maxi threshold value of the DC magnetic operation	7 / 15 In
min/maxi threshold value of the DC thermal operation	1.13 / 1.45 ln

Breaking capacity on 1 pole for IT 400V NF

Rated short circuit breaking capacity Icn under 400V AC according IEC60898-1

Rating current 40°C Rating current 45°C Rating current 50°C Rating current 50°C Rating current 55°C Rating current 60°C Rating current 65°C Rating current 65°C Rating current 70°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Dimensions Depth of installed product 7 Height of installed product	10 k
Rating current -25°C Rating current -20°C Rating current -10°C Rating current -5°C Rating current -5°C Rating current 5°C Rating current 5°C Rating current 10°C Rating current 15°C Rating current 20°C Rating current 20°C Rating current 30°C Rating current 30°C Rating current 30°C Rating current 40°C Rating current 40°C Rating current 55°C Rating current 55°C Rating current 55°C Rating current 55°C Rating current 60°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 50 Hz Dimensions Depth of installed product Rating current of installed product Rating current 20°C Rating current 50°C Rating current 60°C Rating cu	10 k
Rating current -20°C Rating current -10°C Rating current -5°C Rating current 5°C Rating current 5°C Rating current 5°C Rating current 10°C Rating current 10°C Rating current 10°C Rating current 20°C Rating current 20°C Rating current 30°C Rating current 30°C Rating current 30°C Rating current 40°C Rating current 40°C Rating current 55°C Rating current 55°C Rating current 60°C Rating current 60°C Rating current 60°C Rating current 60°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product Rating current installed product Rating current of ratiled product Rating current of trip installed product Rating current of trip current for 4 and 5 devices placed side-by-side Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz	
Rating current -15°C Rating current -10°C Rating current 5°C Rating current 5°C Rating current 5°C Rating current 10°C Rating current 10°C Rating current 10°C Rating current 15°C Rating current 20°C Rating current 20°C Rating current 30°C Rating current 30°C Rating current 35°C Rating current 40°C Rating current 40°C Rating current 5°C Rating current 50°C Rating current 50°C Rating current 50°C Rating current 50°C Rating current 60°C Rating current 60°C Rating current 60°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of rating current for 6 cervices placed side-by-side Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with Correction factor of magnetic tripping with Dimensions Dimensions	7.8
Rating current -10°C Rating current 0°C Rating current 0°C Rating current 10°C Rating current 20°C Rating current 20°C Rating current 25°C Rating current 35°C Rating current 35°C Rating current 40°C Rating current 50°C Rating current 50°C Rating current 60°C Rating current 60°C Rating current 60°C Rating current 70°C Current correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with Correcti	7.7
Rating current 0°C Rating current 10°C Rating current 20°C Rating current 20°C Rating current 30°C Rating current 30°C Rating current 35°C Rating current 40°C Rating current 50°C Rating current 50°C Rating current 60°C Rating current 60°C Rating current 60°C Rating current 60°C Current correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with Corr	7.5
Rating current 0°C Rating current 10°C Rating current 10°C Rating current 10°C Rating current 20°C Rating current 20°C Rating current 20°C Rating current 30°C Rating current 30°C Rating current 35°C Rating current 40°C Rating current 40°C Rating current 50°C Rating current 50°C Rating current 50°C Rating current 60°C Rating current 60°C Rating current 60°C Rating current 60°C Current correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product	7.4
Rating current 10°C Rating current 10°C Rating current 20°C Rating current 20°C Rating current 25°C Rating current 30°C Rating current 30°C Rating current 40°C Rating current 40°C Rating current 55°C Rating current 55°C Rating current 55°C Rating current 55°C Rating current 60°C Rating current 60°C Rating current 60°C Rating current 60°C Current correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product Edight of installed product	7.2
Rating current 10°C Rating current 20°C Rating current 25°C Rating current 30°C Rating current 30°C Rating current 35°C Rating current 40°C Rating current 40°C Rating current 50°C Rating current 50°C Rating current 50°C Rating current 60°C Rating current 70°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product	7.1
Rating current 25°C Rating current 20°C Rating current 25°C Rating current 30°C Rating current 35°C Rating current 35°C Rating current 40°C Rating current 45°C Rating current 45°C Rating current 55°C Rating current 55°C Rating current 60°C Rating current 60°C Rating current 70°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 50 Hz Dimensions Depth of installed product	6.9
Rating current 20°C Rating current 30°C Rating current 35°C Rating current 35°C Rating current 40°C Rating current 40°C Rating current 50°C Rating current 50°C Rating current 50°C Rating current 60°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Dimensions Depth of installed product 7 Height of installed product	6.7
Rating current 30°C Rating current 30°C Rating current 40°C Rating current 40°C Rating current 45°C Rating current 50°C Rating current 50°C Rating current 55°C Rating current 60°C Rating current 60°C Rating current 60°C Rating current 70°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product	6.6
Rating current 30°C Rating current 40°C Rating current 40°C Rating current 45°C Rating current 50°C Rating current 50°C Rating current 55°C Rating current 60°C Rating current 65°C Rating current 65°C Rating current 70°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product Rating current 40°C Rating current 60°C Rating current 60	6.4
Rating current 40°C Rating current 45°C Rating current 50°C Rating current 50°C Rating current 55°C Rating current 60°C Rating current 65°C Rating current 65°C Rating current 70°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Dimensions Depth of installed product 7 Height of installed product	6.2
Rating current 40°C Rating current 50°C Rating current 50°C Rating current 55°C Rating current 60°C Rating current 65°C Rating current 65°C Rating current 65°C Rating current 70°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Dimensions Depth of installed product 7 Height of installed product	6
Rating current 45°C Rating current 50°C Rating current 55°C Rating current 60°C Rating current 65°C Rating current 65°C Rating current 70°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 400 Hz Dimensions Depth of installed product 7 Height of installed product	5.8
Rating current 50°C Rating current 65°C Rating current 65°C Rating current 65°C Rating current 70°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with Bimensions Depth of installed product	5.6
Rating current 55°C Rating current 60°C Rating current 65°C Rating current 70°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with Dimensions Depth of installed product Rating current 60°C Rating current 60	5.4
Rating current 60°C Rating current 65°C Rating current 70°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product 7 Height of installed product	5.2
Rating current 65°C Rating current 70°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 50 Hz Dimensions Depth of installed product 57 Height of installed product	5
Rating current 70°C Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product 57 Height of installed product 8	4.7
Current correction factors Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product 77 Height of installed product 8	4.5
Correction factor of rating current for 2 devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product 77 Height of installed product 8	4.2
devices placed side-by-side Correction factor of rating current for 3 devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product 57 Height of installed product 8	
devices placed side-by-side Correction factor of rating current for 4 and 5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product 7 Height of installed product 8	
5 devices placed side-by-side Correction factor of rating current for 6 devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product 7 Height of installed product	0.9
devices placed side-by-side Correction factor of magnetic tripping with 100 Hz Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product 77 Height of installed product 8	0.
Correction factor of magnetic tripping with 200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product Feight of installed product	0.8
200 Hz Correction factor of magnetic tripping with 400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product 7 Height of installed product 8	1.
400 Hz Correction factor of magnetic tripping with 60 Hz Dimensions Depth of installed product Height of installed product	1.
Dimensions Depth of installed product Height of installed product 8	1.
Depth of installed product Height of installed product 8	
Height of installed product 8	
	70 mr
Width of installed product	33 mr
	35 mr
Frequency	
Frequency 50 to	60 H

Power	
Total power loss under IN	2.5 W
Power loss per pole at In	1.3 W
Endurance	
Electric endurance in number of cycles	4000
Number of mechanical operations	20000
Installation, mounting	
Type of top connection for modular devices	with screw
Tightening torque	2,8Nm
Type of Bottom Connection for modular devices	Blconnect
Connection	
Connection cross-section of input and output with screws, for massive conductors	1 / 35 mm²
Connection cross section of access and exit with screws, for flexible conductor	1 / 25 mm²
Standards	
Standard text	EN 60898-1
European directive WEEE	concerned
Safety	
Protection index IP	IP20
REACH conform	No
RoHS conform	Yes
Halogen free	No
Use conditions	
Operating temperature	-2570 °C
Class of energy limitation I²t	3
Altitude	2000 m

-25...80 °C

Storage/transport temperature